



April 08, 2024

Via Electronic Mail (rphelan@clintonnj.gov)

Town of Clinton
43 Leigh Street
Clinton, New Jersey 08809

Attn: Richard D. Phelan, Public Works/Business Administrator

Re: Town of Clinton, County of Hunterdon, State of New Jersey
2024 End of First Quarter Report
Letter of Water Availability
File No.: SCE-R03765.Y24

Dear Mr. Phelan:

SUBURBAN CONSULTING ENGINEERS, INC. (SCE) offers the following Letter of Water Availability to the Town of Clinton Water Department as a planning tool that may be used by interested parties requesting information of water availability.

The following water availability calculation has been based on a firm capacity calculation as defined by the New Jersey Department of Environmental Protection (NJDEP) in N.J.A.C. 7:10-11.6(a), using a peak daily demand as defined herein and prescribed under N.J.A.C. 7:10-11.4(a)(7).

Water Availability as of April 8, 2024: **14,903 gallons per day (GPD)**

Please be advised the above water availability determination is based on actual water system demand and supply conditions and incorporates all existing water agreements and valid water reservations up to the date of this determination; as such, State published deficit/surplus information may not reflect this amount as it only accounts for reported peak monthly and annual demands and active projects permitted by NJDEP. The above does not account for any pending water reservations or will serve letters issued by the Town.

Future water system reservation applicants are cautioned that the water availability described herein is subject to variation and this letter in no way represents a commitment to serve or a guarantee of allocation for a project at the time of application for water reservation. Should you have any questions, please feel free to contact our office. Thank you.

Very truly yours,

SUBURBAN CONSULTING ENGINEERS, INC.

Anna F. Santino, PE
Project Manager

AFS/jmm

cc: Tara St. Angelo, Town of Clinton Attorney (tstangelo@gklegal.com)