



PWS ID# 1005001

## **Annual Water Quality Report** **Town of Clinton Water Department** **For the Year 2024 Results From 2023**

### **Is my water safe?**

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Landlords must distribute this information to every tenant as soon as practicable, but no later than three business days after receipt. Delivery must be done by hand, mail, or email, and by posting the information in a prominent location at the entrance of each rental premises, pursuant to section 3 of P.L. 2021, c. 82 (C.58:12A-12.4 et seq.).

### **Do I need to take special precautions?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

### **Where does my water come from?**

Our drinking water source consists of 10 ground water wells. These wells draw water from four different aquifers in the area, which are the Brunswick-Shale Aquifer, Kittatinny Limestone Aquifer, Martinsburg Shale Aquifer, and Precambrian Aquifer. The well locations are as follows, 5 wells in the Town of Clinton, 4 wells in Clinton Township, and 1 well in Lebanon Borough.

### **Source water assessment and its availability**

The Source Water Assessment Report and Summary for this public water system is available at [www.state.nj.us/dep/swap](http://www.state.nj.us/dep/swap) or by contacting the NJDEP, Bureau of Safe Drinking Water 609-292-5550.

### **Why are there contaminants in my drinking water?**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses
- Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

### **How can I get involved?**

Any questions or concerns can be addressed by contacting the Town of Clinton Water Department at 908-735-2265.

### **Water Conservation Tips**

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference – try one today and soon it will become second nature.

- Take short showers – a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut of water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They are inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000gallons a month.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit [www.epa.gov/watersense](http://www.epa.gov/watersense) for more information.

### **Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Town of Clinton Water Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800-426-4791) or at <http://www.epa.gov/safewater/lead>.

**Source Water Assessment Report**, The New Jersey Department of Environmental Protection (NJDEP) has completed and issued the Source Water Assessment Report and Summary for this public water system, which is available at <http://www.nj.gov/dep/watersupply/swap/index.html>, or by contacting the NJDEP, Bureau of Safe Drinking Water at 609-292-5550 or [watersupply@dep.nj.gov](mailto:watersupply@dep.nj.gov).

# Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

<u>Contaminants</u>	<u>MCLG</u> or <u>MRDLG</u>	<u>MCL,</u> <u>TT, or</u> <u>MRDL</u>	<u>Your</u> <u>Water</u>	<u>Range</u>		<u>Sample</u> <u>Date</u>	<u>Violation</u>	<u>Typical Source</u>
				<u>Low</u>	<u>High</u>			
<b>Disinfectants &amp; Disinfectant By-Products</b>								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Haloacetic Acids (HAA5) (ppb)	NA	60	1.73	0.78	4.0	2023	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	14.7	4.2	21	2023	No	By-product of drinking water disinfection
Chlorine (as C12 ppm)	4	4	0.5	0.33	0.69	2023	No	Water Additive used to control microbes
<b>Inorganic Contaminants</b>								
Nitrate [measured as Nitrogen] (ppm)	10	10	2.9	.13	6.3	2023	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Arsenic (ppb)	0	5	<2	<.002	<2	2023	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.

<u>Contaminant</u>	<u>MCLG</u> or <u>MRDLG</u>	<u>MCL,</u> <u>TT, or</u> <u>MRDL</u>	<u>Your</u> <u>Water</u>	<u>Range</u>		<u>Sample</u> <u>Date</u>	<u>Violation</u>	<u>Typical Source</u>
				<u>Low</u>	<u>High</u>			
<b>Microbiological Contaminants</b>								
Total Coliform (positive samples/month)	0	0	0	NA	NA	2023	No	Naturally present in the environment
Fecal Coliform / e.coli – in the distribution system (positive samples)	0	0	0	NA	NA	2023	No	Human and animal fecal waste
Total coliform bacteria are used in coliform sampling as an indicator organism that harmful and pathogenic bacteria may be present. Generally, coliforms are bacteria that are not harmful and are naturally present in the environment, however, are used as an indicator that fecal bacteria could be present. If routine or repeat sampling events are total coliform positive, further analysis must be performed to determine if E. coli are present. No E. coli bacteria were found during the routine and repeat sampling event. A violation occurs when a routine sample and a repeat sample, in any given month, are total coliform positive, and one is also fecal coliform or E. coli positive								

Radioactive Contaminants								
Radium (combined 226/228) (pCi/L)	0	5	.36	< 1	2.31	2023	No	Erosion of natural deposits
<u>Contaminants</u>	<u>MCLG</u>	<u>AL</u>	<u>Your Water</u>	<u>Sample Date</u>	<u># Samples Exceeding AL</u>	<u>Exceeds AL</u>	<u>Typical Source</u>	
Inorganic Contaminants								
Copper - action level at consumer taps (ppm)	0	1.3	0.228	2023	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	
Lead - action level at consumer taps (ppb)	0	15	2	2023	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	
<p>"If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from minerals and components associated with service lines and home plumbing. The Clinton Water Dept. is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water is available from the Safe Drinking Water Hotline or at, <a href="http://www.epa.gov/safewater/lead">http://www.epa.gov/safewater/lead</a>. "</p>								
Synthetic Organic Compounds								
<u>Contaminants</u>	<u>MCLG</u>	<u>MCL, TT</u>	<u>Your Water</u>	<u>Range Low High</u>		<u>Sample Date</u>	<u>Violation</u>	<u>Typical Source</u>
PFNA (PFAS)	0	13 ppt	<2	<2	<2	2023	No	Per and Polyfluoroalkyl Substances (PFAS) are a group of manmade chemicals used to make fluoropolymer coatings and products that resist heat, oil, stains, grease and water.
PFOS (PFAS)	0	13 ppt	3.94	<2	9.7	2023	No	Per and Polyfluoroalkyl Substances (PFAS) are a group of manmade chemicals used to make fluoropolymer coatings and products that resist heat, oil, stains, grease and water.
PFOA (PFAS)	0	14 ppt	5.3	<2	8.8	2023	No	Per and Polyfluoroalkyl Substances (PFAS) are a group of manmade chemicals used to make fluoropolymer coatings and products that resist heat, oil, stains, grease and water.
123 TCP	0	.03 ppb	< .0246	< .024 < .025		2023	No	Exposure occurs from industrial settings or hazardous waste site.
EDB	0	.05 ppb	< .0050	< .005 < .0032		2023	No	Exposure occurs from industrial settings or hazardous waste site.
DBCP	0	0.2 ppb	< .0030	< .003 < .0032		2023	No	Exposure occurs from industrial settings or hazardous waste site.

## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

### Availability of Monitoring Data for Unregulated Contaminants for Clinton Water Dept.

Our water system has sampled for a series of unregulated contaminants. Unregulated contaminants are those that don't yet have a drinking water standard set by the EPA. The purpose of monitoring for these contaminants is to help the EPA decide whether the contaminants should have a standard. As our customers, you have a right to know that these data are available. If you are interested in examining the results, please contact the Clinton Water Department at (908)735-2265 or 43 Leigh Street Clinton, NJ 08809.

This notice is being sent to you by the Clinton Water Department. System ID#: 1005001

Date distributed: May 1, 2024

Name	Reported Average Level Ug/l – ppb	Range		Typical Source
		High	Low	
Lithium	3.45 ug/l	17.7	<9	Naturally occurring in rocks and soils.

## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

### Monitoring and Reporting Requirements Not Met for Clinton Water Department

Our water system violated drinking water requirements during the second quarter cycle. Even though these were not emergencies, as our customers, you have a right to know what happened and what we are doing to correct the situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the second quarter monitoring period of 04/01/2023 thru 06/30/2023, we did not monitor or test for STAGE 2 TTHM-HAA5, which are disinfection byproducts and therefore cannot be sure of the quality of your drinking water during that time.

### What should I do?

There is nothing you need to do at this time.

We had the sampling stations re-sampled in July with compliant results and are back on schedule with satisfactory sample results at this point.

Please share this information with all other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or by distributing copies by hand or mail.

For more information, please contact, Art Dysart, Superintendent @ (908)735-2265

This notice is being sent to you by The Clinton Water Dept. System ID# 1005001

<b>Unit Descriptions</b>	
<b>Term</b>	<b>Definition</b>
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
positive samples/month	positive samples/month: Number of samples taken monthly that were found to be positive
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

<b>Important Drinking Water Definitions</b>	
<b>Term</b>	<b>Definition</b>
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level
MRL	MRL: Minimum Reporting Level

For more information please contact:

Arthur A. Dysart, Water Superintendent  
Town of Clinton Water Department  
43 Leigh Street, P.O. Box 5194  
Clinton, NJ 08809  
Phone: 908-735-2265  
www.clintonnj.gov


This notice is being sent to you by the  
Town of Clinton Water Department  
State Water System ID #1005001  
Date distributed: May 2024

We at The Town of Clinton Water Department work hard to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call our office if you have any questions at 908-735-2265.

**TOWN OF CLINTON WATER DEPARTMENT**



**HELP CONSERVE WATER CHECK YOUR  
FAUCETS AND TOILETS  
FOR LEAKS**



## **TOWN OF CLINTON**

INCORPORATED APRIL 5, 1865

43 Leigh St., P.O. Box 5194

Clinton, N.J. 08809-5194

(908) 735-8616 FAX (908) 735-8082

Date of Notice: May 2024

# **ATTENTION**

## **TOWN OF CLINTON WATER CUSTOMERS**

### **WATER RESTRICTIONS**

(TOWN OF CLINTON, BORO OF LEBANON, CLINTON, FRANKLIN, & UNION TOWNSHIP)

DUE TO THE CURRENT WATER DEMAND, THE SYSTEM HAS BEEN RUNNING VERY CLOSE TO THE SYSTEM'S ANNUAL MAXIMUM ALLOWABLE ALLOCATION SET BY THE NJDEP. THEREFORE, IT WILL BE NECESSARY TO REMAIN ON THE WATER RESTRICTIONS THAT ARE PRESENTLY IN AFFECT. THESE RESTRICTIONS WILL NOT ONLY HELP MAINTAIN THE INTEGRITY OF THE SYSTEM, BUT WILL ALSO ASSURE ADEQUATE WATER FOR FIRE PROTECTION.

#### MANDATORY WATER RESTRICTIONS ARE NOW IN EFFECT UNTIL FURTHER NOTICE

1. USE OF LAWN IRRIGATION SYSTEMS IS PROHIBITED. WATERING OF LAWNS, GARDENS, AND SHRUBBERY IS PERMITTED **ONLY** BY USE OF A HAND HELD DEVICE.
  2. WASHING OF ANY TYPE OF VEHICLE IS PROHIBITED. AUTOMATIC CAR WASHES ARE EXEMPT BECAUSE THEY RECYCLE 90% OF WATER USED.
  3. DUE TO THE LOW VOLUME OF WATER USED BY PRESSURE WASHERS, THEIR USE IS PERMITTED TO CLEAN OUTDOOR SURFACES.
- A. VIOLATIONS OF THESE RESTRICTIONS SHALL RESULT IN DISCONTINUANCE OF WATER SERVICE WITH A \$100.00 FEE TO HAVE SERVICE RESUMED.
- B. IN ADDITION, ANY PERSON, FIRM OR CORPORATION VIOLATING ANY OF THE PROVISIONS OF THESE RESTRICTIONS SHALL BE FINED IN AN AMOUNT NOT EXCEEDING ONE THOUSAND DOLLARS (\$1,000.) FOR EACH VIOLATION HEREOF. EACH DAY SUCH VIOLATION IS COMMITTED OR PERMITTED TO CONTINUE SHALL CONSTITUTE A SEPARATE OFFENSE AND SHALL BE PUNISHABLE AS SUCH HEREUNDER.



**TOWN OF CLINTON WATER DEPT.**

43 Leigh Street  
P.O. Box 5194  
Clinton, NJ 08809

STANDARD MAIL  
US POSTAGE  
PAID  
FLEMINGTON, NJ  
Permit No. 258